


NOTES:

1. D = INSIDE DIAMETER OF PIPE.
2. TRENCH WIDTHS ARE SET TO ESTABLISH PAY LIMITS ONLY.
3. ALL EXCAVATIONS MUST MEET OSHA STANDARDS
4. CONTRACTOR TO PROVIDE COMPACTION ON ALL TRENCH BACKFILLS, EXCAVATIONS AND PAVEMENT BASES TO NOT LESS THAN 95% OF THE DRY DENSITY FOR THAT MATERIAL.
5. BEDDING MATERIAL TO CONFORM TO M.08.01.21 MAXIMUM AS PER CT DOT DORM 816.

Dwg. No. W-1		Trench Detail: Water Main & Service			Date: May 2014
Revision	Date	Drawn	Scale	Description	
Water Construction Standards				Norwich Public Utilities	